

Renewable Heat Incentive

Non-domestic Renewable Heat Incentive Emissions Certificate



This certificate provides evidence that the tested boiler meets the air quality requirements of the non-domestic Renewable Heat Incentive (RHI) – Reg5A(3) and Schedule A1. It must be issued by a testing laboratory. Applicants applying for the RHI with biomass boilers must submit a certificate with their application, or alternatively, an environmental permit.

1. TEST HOUSE	
a) name and address of testing laboratory	The Engineering Test Institute, Public Enterprise Hudcova 424/56b, 621 00 Brno, Czech Republic tel.: 00420 541 120 330 e-mail.: holomek@szutest.cz web: www.szutest.cz
b) name and signature of the person authorised by the testing laboratory to issue the certificate	Name: Mr. Milan Holomek Head of Heat and Environment-Friendly Equipment Test Station Signature:
c) date of issue of this certificate together with certificate reference number *Please see Note A	Date: 10/02/2017 Ref: SZUBR230
d) if testing laboratory is accredited to BS EN ISO/IEC 17025:2005, date of accreditation and accreditation number (note: if testing conducted after 24 September 2013,	Date: 13/05/2016 Accreditation number: 292/2016
the testing laboratory must be BS EN ISO/IEC 17025:2005 accredited)	7 TOO TOO TOO TOO TOO TOO TOO TOO TOO TO

2. PLANT		
Please see Note B		
a) name of the plant tested	SMART 525	
no) model of the plant tested	SMART 525	
c) manufacturer of the plant tested	Smart Heating Technology s.r.o. U Statku 653/24, 717 00 Ostrava - Bartovice Czech Republic	
d) installation capacity* of the tested plant in kilowatts (kW)	525 kW	
defined in the RHI Regulations as the total installed beak heat output capacity of the plant		

e) is the plant a <u>manually stoked, natural draught</u> plant? (that is, without a fan providing forced or induced draught)	no, automatic
f) (i) the date the plant was tested* (ii) please confirm that NOx and PM have been tested on the same occasion *This is in reference to the emissions testing for PM and NOx, not any wider range of tests. A specific date is required.	08/02/2017 yes
g) list of all the plants in the type-testing range* of plants to which the certificate applies, if any¹ Please include the installation capacity of each model. *This must follow the ratio rules: If the smallest plant in the range is 500kW or less, the largest plant in the range can't be more than double the smallest. If the smallest plant in the range is over 500kW, the largest plant in the range can't be more than 500kW greater than the smallest.	SMART 525 – 525 kW

3. FUELS	
a) types of fuels used when testing	Wood pellets – C1
b) based on the testing, list the range of fuels that can be used	Wood pellets – C1
in compliance with the emission limits of 30 grams per gigajoule	according to
(g/GJ) net heat input for particulate matter (PM), and 150 g/GJ	BS EN 303-5:2012
net heat input for oxides of nitrogen (NOx)	(ČSN EN 303-5:2013)
(based if relevant on classifications from EN14961 or EN303-5)	(,
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
c) moisture content of the fuel used during testing	6.58%
,g	
d) maximum moisture content of the fuel which can be used	12%
with the certified plant(s) so as to ensure that the RHI emission	1270
limits are not exceeded.	
illinis are not exceeded.	

4. TESTS

Confirm which requirements the emissions of NOx and PM have been tested in accordance with. <u>Either 4a or 4b should be confirmed, the other should be 'not applicable'</u>

a) if the testing was carried out in accordance with the provisions relevant to emissions of PM and NOx in either BS EN 303-5:1999 or BS EN 303-5:2012², please confirm:

-thetest was conducted to whichever standard was current at the time of testing.

BS EN 303-5:2012 (ČSN EN 303-5:2013): yes

² BS EN303-5:1999 and 2012 explain what should be measured and when. ³ These standards explain how to make the PM and NOx measurements.

¹ The type-testing approach enables testing laboratories to provide assurance that all boilers in a given range meet the air quality requirements, without needing to specifically test each boiler.

b) if the testing was carried out in accordance with the following requirements, please confirm: (i) testing was carried out in accordance with: - EN 14792:2005 in respect of NOx emissions, and;	
 EN 13284-1:2002 or ISO 9096:2003 in respect of PM emissions³; and (ii) emissions of PM represent the average of at least three measurements of emissions of PM, each of at least 30 minutes duration; and 	not applicable
(iii)the value for NOx emissions is derived from the average of measurements made throughout the PM emission tests.	
c) please confirm the plant was tested at ≥85% of the installation capacity of the plant	yes
d) please confirm the test shows that emissions from the plant were no greater than 30g/GJ PM and150g/GJ NOx	yes
 e) measured* emissions of PM in g/GJ net heat input *this value should be from the test confirmed in 4c. Results from partial load tests are not required. This value must be in the specified units. 	7 g/GJ
f) measured* emissions of NOx in g/GJ net heat input *this value should be from the test confirmed in 4c. Results from partial load tests are not required. This value must be in the specified units.	54 g/GJ

Note A: If details from a previously issued certificate are being transferred to this RHI emission certificate template, please note that this document must be **issued by the testing laboratory** as a separate certificate. So the issue date and certificate reference number should be in relation to *this* certificate using the RHI template, not the issue date and reference number of the original certificate.

Note B: If you are including multiple tested plants on one certificate, please ensure that all sections are completed for each tested plant, and are laid out such that it is clear which details relate to which tested plant. If a type-testing range is included as well, please show clearly which type-testing range relates to which tested plant(s), following the type-testing range ratio rules outlined in 2g.

