

Boiler Setting – Smart 60 kW					
IP CU – 192.168.1.42, Net mask 255.255.255.0, port 4242			ADMIN, SBTAdmin!		
IP from Internet – _____			Tel. modem:		
Output	Pause MAX Output		39	s	
	Pause MIN Output		100	s	
	Feed Time		2	s	
	First Feed – Ignition		12	s	
Ignition	Red Hot Time		6	min	
	Temp Exhaust Gas		50	°C	
	Space between ign.		30	s	
	Repeat		7		
	Exh against boiler		3	K	
	Exh hyst. against boiler		3	K	
	Feeding between ign.		40	%	
	Enable cold start		on		
	Feed cold start		2	s	
	Cold start Pause		32	s	
	Cold start max. time		4	min	
	Exh. Gas difference		10	K	
<b>Fans</b>	<b>% of Output</b>	<b>Primary Fan</b>	<b>Secondary Fan1</b>	<b>Secondary Fan2</b>	
	P 30 %	50	40		%
	P 40 %	55	45		%
	P 50 %	60	50		%
	P 60 %	65	55		%
	P 70 %	70	60		%
	P 80 %	75	65		%
	P 90 %	80	70		%

Boiler Setting – Smart 60 kW					
	P 100 %	85	75		%
	Ignition	60	60	no	%
	Run Out	5		min	
Engines	M3 Deashing	Deashing running with M2 Fuel feeder			
	M3 Run				
	M6 Burn_Clean	8	Cycle		
	M6 Run	5	s		
	M4/M5 Exch_clean	160	Cycle		
	M4/M5 Run	25	s		
	M1 Maxtime feeding	15	min		
	Time for st test	60	s		
Valves	Time				
	Open	120	s		
	Close	120	s		
Pumps	Pump Shunt	48/80	°C		
Temperatures	Boiler	80	°C		
	Return Water	55	°C		
	B2 Boiler On hyst	1	°C		
	B2 Boiler Off hyst	3	°C		
	B4 Buffer hyst On	5	°C		
	B41 Buffer hyst Off	0	°C		
Underpressure	Normal	25	Pa		
	Standby	8	Pa		
	Of Time	20	min		