

Boiler Setting – Smart 60 kW					
IP CU – 192.168.1.42, Net mask 255.255.255.0, port 4242			ADMIN, SBTAdmin!		
IP from Internet – _____			Tel. modem:		
Output	Pause MAX Output		15	s	
	Pause MIN Output		60	s	
	Feed Time		5	s	
	First Feed – Ignition		20	s	
Ignition	Red Hot Time		7	min	
	Temp Exhaust Gas		50	°C	
	Space between ign.		30	s	
	Repeat		7		
	Exh against boiler		3	K	
	Exh hyst. against boiler		3	K	
	Feeding between ign.		70	%	
	Enable cold start		on		
	Feed cold start		4	s	
	Cold start Pause		30	s	
	Cold start max.time		4	min	
	Exh. Gas difference		10	K	
Fans	% of Output	Primary Fan	Secondary Fan1	Secondary Fan2	
	P 30 %	50	40		%
	P 40 %	55	45		%
	P 50 %	60	50		%
	P 60 %	65	55		%
	P 70 %	70	60		%
	P 80 %	75	65		%
	P 90 %	80	70		%

Boiler Setting – Smart 60 kW					
	P 100 %		85	75	%
	Ignition		60	60	no %
	Run Out		5		min
Engines	M3 Deashing	Deashing running with M2 Fuel feeder			
	M3 Run				
	M6 Burn_Clean		8	Cycle	
	M6 Run		5	s	
	M4/M5 Exch_clean		160	Cycle	
	M4/M5 Run		25	s	
	M1 Maxtime feeding		15	min	
	Time for st test		60	s	
Valves	Time				
	Open		120	s	
	Close		120	s	
Pumps	Pump Shunt		48/80	°C	
Temperatures	Boiler		80	°C	
	Return Water		55	°C	
	B2 Boiler On hyst		1	°C	
	B2 Boiler Off hyst		3	°C	
	B4 Buffer hyst On		5	°C	
	B41 Buffer hyst Off		0	°C	
Underpressure	Normal		25	Pa	
	Standby		8	Pa	
	Of Time		20	min	