SMART REFERENCE LIST | SMART INDIVIDUAL INSTALLATION SOLUTION 150 KW

BASIC SCHOOL, TOWN OF FAYETTE, MAINE, US





SMART REFERENCE LIST | SMART INDIVIDUAL INSTALLATION SOLUTION 150 KW

BASIC SCHOOL, TOWN OF FAYETTE, MAINE, US









Fuel	Actual use reported for heating year:			
	July 2012 to June 2013	July 2013 to June 2014	July 2014 to June 2015	July 2015 to June 2016
Pellets				
Used (tons)	1.00	55.75	85.56	57.33
Actual Cost (fuel + shipping)	\$175.00	\$10,035.00	\$15,041.00	\$11.321.15
Oil				
Used (gallons)	8,230.00	1,755.00	708.00	168.80
Actual Cost (fuel + shipping)	\$25,431.00	\$5,874.00	\$2,260.00	\$263.16
Total Cost (total both Actual Costs)	\$25,606.00	\$15,909.00	\$17,301.00	\$11.584.31



