



Strojírenský zkušební ústav, s.p.
(Engineering Test Institute, Public Enterprise)
Testing Laboratory 1045.1, Workplace 1
Accredited by the Czech Accreditation Institute
Hudcova 424/56b, 621 00 Brno, Czech Republic

Page 1 of 9



TEST REPORT

39-10872/1

Product: Hot-water boilers for wood chips
and wood pellets

Type designation: SMART 499

Customer: Smart Heating Technology s.r.o.
U Statku 653/24, 717 00 Ostrava - Bartovice
Czech Republic
Company ID No.: 28616774

Manufacturer: Smart Heating Technology s.r.o.
U Statku 653/24, 717 00 Ostrava - Bartovice
Czech Republic

Employee responsible: Mr. Milan Holomek

Report issue date: 2016-05-16

Distribution list: 1 copy to the Customer
1 copy to the Engineering Test Institute

This report may be copied in its entirety without written consent of the Engineering Test Institute.
Partial copies are subject to approval.
The results of tests and verifications relate only to the products tested.



The tests were carried out based on these documents:

- Order B-55787 of 2016-04-27 (Order reg. no. B-55787, received on 2016-04-27)

I. Product description

The SMART 499 steel hot-water boiler is intended for central heating of houses, office blocks, industrial premises etc. The fuels to be used under the warranty are wood chips – B1 and wood pellets – C1.

The boiler body consists of a combustion chamber and a vertical tubular exchanger. The combustion chamber is fitted with a retort burner with holes to let in primary combustion air. Two perforated hollow burner rings for supply of secondary combustion air are placed above it. The boiler is equipped with one radial fan for supply of primary air and two radial fans for supply of secondary air. A screw feeder brings the fuel from the operational bin through the centre of the burner. The feeder is fitted with an extinguishing device to prevent back-burning. The ash falls over the burner edge and it is cyclically removed by screws into an ash bin on the boiler side. The tubular heat exchanger is fitted with revolving turbulators, which together with motor drive clean the exchanger. Part of the boiler is a cyclone separator that is connected to the flue gas outlet ducting. On the outlet side, the separator is fitted with a radial fan with electronic speed control to ensure that negative pressure is maintained in the combustion chamber. The feeding screw is joined to the operational fuel bin with an inbuilt separation valve against the back draught.

The boiler body is doubly insulated: one layer of 80 mm Rotaflex mineral wool is inserted on the side of the boiler and the other layer of 50 mm Orsil mineral wool is inserted under the boiler steel casing.

As opposed to the certification tests, the boiler has additionally been fitted with a cased pocket fabric filter with automatic regeneration of the filtration medium by compressed air.

II. Sample tested

| Boiler capacity version | Fuel | Output [kW] | Place of testing |
|-------------------------|----------------------------------|-------------|------------------|
| SMART 499 | Wood pellets C1 Wood chips B1 | 499 | Watford |

The visual inspection, tests and evaluations were carried out by Ing. Pavel Fojtů, Test Engineer, at Watford, in 05/2016.

The tests were performed with validly calibrated measuring and test equipment.



III. Test results

Measuring and test equipment

| No. | Description | Inventory number | Calibration valid until: | Accuracy |
|-----|---|------------------|--|--|
| 1. | Combustion products analyser, Horiba, type 680 P | 92-0004 | Calibration prior to every measurement | See CRM 103000237769 See CRM 103000237770 |
| 2. | Scale | 02-2290 | 10/2017 | See Calibration Sheet 6051-KL-H-0168-13 |
| 3. | Water meter, NW 20 | 02-1575 | 10/2017 | See Calibration Sheet AKL-P/006/2009 |
| 4. | Measuring centre | 02-2241 | 12/2016 | See Calibration Sheet 130129 |
| 5. | Hygrometer, thermometer | 11-6258 | 11/2017 | See Calibration Sheet 8346F/12 |
| 6. | Barometer | 11-2541 | 01/2019 | See Calibration Sheet 6013-KL-K001 |
| 7. | Draught gauge | 11-7275 | 10/2017 | See Calibration Sheet 1165F/13 |
| 8. | Stop watch | 99-0760 | 11/2017 | See Calibration Sheet 2955E-12 |
| 9. | Calorimeter, IKA, type C 5000 | 02-2236 | Calibration prior to every measurement | ± 0.12 MJ/kg |
| 10. | Elemental analyser, Perkin Elmer, type 2400 CHNS) | 02-2107 | Calibration prior to every measurement | ± 0.2 % rel. |
| 11. | Gravimat SHC 501 | 02-2328 | 10/2017 | See Calibration Sheet 120080-120084 |
| 12. | Laboratory scale | 02-1458 | 10/2017 | See Calibration Sheet 6051-KL-H0403-13 |
| 13. | Scale, Ohaus MB 45 | 02-2274 | 10/2017 | See Calibration Sheet 6051-KL-H0400-13 |
| 14. | Pressure gauge | 111985 | 04/2019 | See Calibration Sheet 090162 |
| 15. | Prandtl tube, 0.3 m | ME 484 | 11/2017 | See Calibration Sheet 5012-KL-RS090-09 |
| 16. | Psychro-meter, C455 | 022007 | 10/2017 | See Calibration Sheet 090176 |
| 17. | Electrometer | 03524781 | 03/2022 | See Calibration Sheet 002/12/E |

| No. | Name and specification | Technical standard, regulation applied | Source materials | Evaluation | |
|-----|---|--|------------------|------------|------------|
| | | | | Tests | Evaluation |
| 1. | Test of combustion efficiency – emissions (1005.1*) | ČSN EN 303-5:2013 Art. 4.4.7, 5.7.3, 5.7.4, 5.9, 5.10.4 | Pages 12 - 13 | + | (*) |

Note:

No.:

(*) - The emissions of CO and OGC were not measured.

Evaluation:

+ Requirement fulfilled
 - Requirement not fulfilled
 x Not assessed
 0 Not applicable



Accredited test number: **1005.1*** Test title: **Combustion efficiency test – emissions**

Test method: ČSN EN 303-5:2013 Art. 4.4.7, 5.7.3, 5.7.4, 5.9, 5.10.4

Sample tested: SMART 499

Measuring equipment used: Chapter III – Measuring and test equipment

| Requirement | Requirement specification | Test evaluation | Note |
|---|------------------------------|-----------------|------|
| Emission limits Combustion shall be of low-emission. This requirement shall be satisfied if the emission values shown in Table 6 are not exceeded when operating at nominal heat output or, in the case of boilers with heat output range, when operating at nominal heat output and minimum heat output, in accordance with 5.7, 5.9 and 5.10. | ČSN EN 303-5:2013 Art. 4.4.7 | + (*) | |

Note: (*) – The emissions of CO and OGC were not measured.

Table 6

| Fuel supply | Fuel | Nominal heat output kW | Emission limits mg/m ³ at 10% O ₂ | | | | | | | | |
|-------------|----------|---------------------------|--|-------|-------|---------|-------|-------|-------|-------|-------|
| | | | CO | | | OGC/THC | | | Dust | | |
| | | | Class | Class | Class | Class | Class | Class | Class | Class | Class |
| Manual | Biogenic | ≤ 50 | 5000 | 1200 | 700 | 150 | 50 | 30 | 150 | 75 | 60 |
| | | > 50 ≤ 150 | 2500 | | | 100 | | | 150 | | |
| | | > 150 ≤ 500 | 1200 | | | 100 | | | 150 | | |
| | Fossil | ≤ 50 | 5000 | | | 150 | | | 125 | | |
| | | > 50 ≤ 150 | 2500 | | | 100 | | | 125 | | |
| | | > 150 ≤ 500 | 1200 | | | 100 | | | 125 | | |
| Automatic | Biogenic | ≤ 50 | 3000 | 1000 | 500 | 100 | 30 | 20 | 150 | 60 | 40 |
| | | > 50 ≤ 150 | 2500 | | | 80 | | | 150 | | |
| | | > 150 ≤ 500 | 1200 | | | 80 | | | 150 | | |
| | Fossil | ≤ 50 | 3000 | | | 100 | | | 125 | | |
| | | > 50 ≤ 150 | 2500 | | | 80 | | | 125 | | |
| | | > 150 ≤ 500 | 1200 | | | 80 | | | 125 | | |

NOTE 1 The dust values in this Table are based on the experience of the gravimetric filter method. The method used needs to be referred to in the test report. The particulate matter emission measured according to this European Standard does not include condensable organic compounds which may form additional particulate matter when the flue gas is mixed with ambient air. The values are therefore not directly comparable with values measured by dilution tunnel methods. Neither can they be directly translated into ambient air particulate concentrations.

NOTE 2 Additional test methods and emission limits which apply in some countries are given in the A-Deviations in Annex C.

^a Referred to dry exit flue gas, 0 °C, 1013 mbar.

^b Boilers of class 3 for type E-fuels according to 1.2.1 or e-fuels according to 1.2.3 in this Table and marked with the classification E-fuels and e-fuels do not need to fulfil the requirements for the dust emissions. The actual value shall be stated in the technical documentation and shall not exceed 200 mg/m³ at 10 % O₂.



Measurement results: SMART 499, wood pellets – C1 (nominal output)

| Date of sampling | Sample designation | Sampling location | Flue gas temperature (°C) | Measured O ₂ (%) | Extraction volume (m ³) | Difference in sample weight (mg) |
|------------------|--------------------|-------------------|---------------------------|-----------------------------|-------------------------------------|----------------------------------|
| 4.5.2016 | 10,0-2605 | Before filter | 103 | 6.0 | 0.860 | 8.5 |
| | 10,0-2624 | | 120 | 6.0 | 0.707 | 9.3 |
| | 10,0-2596 | After filter | 87 | 6.5 | 0.649 | 1.1 |
| | 10,0-2620 | | 87 | 6.5 | 0.560 | 0.5 |
| | 10,0-2613 | | 95 | 6.5 | 0.564 | 0.7 |

| Sample designation | Sampling location | Sample volume in n. c. (l) | Dry sample volume in n. c. (l) | Dust concentration (mg/m ³) | Dust concentration converted to 10% O ₂ (%) | Resultant dust concentration converted to 10% O ₂ (%) |
|--------------------|-------------------|----------------------------|--------------------------------|---|--|--|
| 10,0-2605 | Before filter | 625 | 531 | 16 | 12 | 14 |
| 10,0-2624 | | 491 | 418 | 22 | 16 | |
| 10,0-2596 | After filter | 492 | 418 | 3 | 2 | 2 |
| 10,0-2620 | | 425 | 361 | 1 | 1 | |
| 10,0-2613 | | 418 | 356 | 2 | 1 | |

Note: Only the concentration of dust particles was measured (the concentration of CO, NO_x, SO₂ and THC/OGC was not measured).



Measurement results: SMART 499, wood pellets – C1 (minimum output)

| Date of sampling | Sample designation | Sampling location | Flue gas temperature (°C) | Measured O ₂ (%) | Extraction volume (m ³) | Difference in sample weight (mg) |
|------------------|--------------------|-------------------|---------------------------|-----------------------------|-------------------------------------|----------------------------------|
| 4.5.2016 | 10,0-213 | Before filter | 77 | 11.0 | 0.796 | 4.3 |
| | 10,0-2402 | | 77 | 11.0 | 0.631 | 4.3 |
| | 10,0-2634 | After filter | 70 | 11.2 | 0.553 | 0.4 |
| | 10,0-2587 | | 68 | 11.2 | 0.549 | 0.5 |
| | 10,0-214 | | 65 | 11.2 | 0.561 | 1.0 |

| Sample designation | Sampling location | Sample volume in n. c. (l) | Dry sample volume in n. c. (l) | Dust concentration (mg/m ³) | Dust concentration converted to 10% O ₂ (%) | Resultant dust concentration converted to 10% O ₂ (%) |
|--------------------|-------------------|----------------------------|--------------------------------|---|--|--|
| 10,0-213 | Before filter | 621 | 528 | 8 | 9 | 10 |
| 10,0-2402 | | 492 | 418 | 10 | 11 | |
| 10,0-2634 | After filter | 440 | 374 | 1 | 1 | 2 |
| 10,0-2587 | | 440 | 374 | 1 | 2 | |
| 10,0-214 | | 453 | 385 | 3 | 3 | |

Note: Only the concentration of dust particles was measured (the concentration of CO, NO_x, SO₂ and THC/OGC was not measured).



Measurement results: SMART 499, wood chips – B1 (nominal output)

| Date of sampling | Sample designation | Sampling location | Flue gas temperature (°C) | Measured O ₂ (%) | Extraction volume (m ³) | Difference in sample weight (mg) |
|------------------|--------------------|-------------------|---------------------------|-----------------------------|-------------------------------------|----------------------------------|
| 4.5.2016 | 8,0-2401 | Before filter | 81 | 9.5 | 0.803 | 14.4 |
| | 8,0-2491 | | 81 | 9.5 | 0.813 | 11.5 |
| | 8,0-2850 | After filter | 75 | 8.5 | 0.362 | 4.0 |
| | 8,0-3022 | | 75 | 9.0 | 0.382 | 4.1 |

| Sample designation | Sampling location | Sample volume in n. c. (l) | Dry sample volume in n. c. (l) | Dust concentration (mg/m ³) | Dust concentration converted to 10% O ₂ (%) | Resultant dust concentration converted to 10% O ₂ (%) |
|--------------------|-------------------|----------------------------|--------------------------------|---|--|--|
| 8,0-2401 | Before filter | 616 | 524 | 28 | 26 | 24 |
| 8,0-2491 | | 624 | 530 | 22 | 21 | |
| 8,0-2850 | After filter | 284 | 241 | 17 | 15 | 15 |
| 8,0-3022 | | 300 | 255 | 16 | 15 | |

Note: Only the concentration of dust particles was measured (the concentration of CO, NO_x, SO₂ and THC/OGC was not measured).



Measurement results: SMART 499, wood chips – B1 (minimum output)

| Date of sampling | Sample designation | Sampling location | Flue gas temperature (°C) | Measured O ₂ (%) | Extraction volume (m ³) | Difference in sample weight (mg) |
|------------------|--------------------|-------------------|---------------------------|-----------------------------|-------------------------------------|----------------------------------|
| 3.5.2016 | 6,4-2459 | Before filter | 70 | 10.5 | 0.236 | 40.0 |
| | 6,4-2820 | | 68 | 10.5 | 0.223 | 31.3 |
| | 6,4-2425 | | 65 | 10.5 | 0.214 | 35.4 |
| | 6,4-2444 | After filter | 45 | 10.5 | 0.270 | 4.8 |
| | 8,0-213 | | 45 | 10.5 | 0.290 | 5.2 |
| | 8,0-2526 | | 45 | 10.5 | 0.401 | 4.5 |

| Sample designation | Sampling location | Sample volume in n. c. (l) | Dry sample volume in n. c. (l) | Dust concentration (mg/m ³) | Dust concentration converted to 10% O ₂ (%) | Resultant dust concentration converted to 10% O ₂ (%) |
|--------------------|-------------------|----------------------------|--------------------------------|---|--|--|
| 6,4-2459 | Before filter | 188 | 160 | 251 | 262 | 244 |
| 6,4-2820 | | 179 | 152 | 206 | 216 | |
| 6,4-2425 | | 173 | 149 | 241 | 252 | |
| 6,4-2444 | After filter | 232 | 197 | 24 | 26 | 23 |
| 8,0-213 | | 249 | 212 | 25 | 26 | |
| 8,0-2526 | | 344 | 293 | 15 | 16 | |

Note: Only the concentration of dust particles was measured (the concentration of CO, NO_x, SO₂ and THC/OGC was not measured).


Tested by: Ing. Pavel Fojtů

Date: 05/2016

Signed: 

Reviewed by: Ing. Stanislav Buchta

Date: 05/2016

Signed: 



The test methods indicated in this Report were applied without any deviations, additions or exceptions.

IV. A list of referenced background materials

- Order B-55787 of 2016-04-27 (received on 2016-04-27)
- ČSN EN 303-5:2013 – Heating boilers – Part 5: Heating boilers for solid fuels, manually and automatically stoked, nominal heat output of up to 500 kW – Terminology, requirements, testing and marking
- ČSN ISO 80000-1:2011 – Quantities and units – Part 1: General

Report compiled by: Ing. Pavel Fojtů

Person responsible for correctness of the Report:



Milan Holomek
Head of Heat and Environment-Friendly Equipment Test Station